

**GENERAL NOTES:**

1. ALL CORNERS ARE TO BE CHAMFERED 1" IF CONCRETE.
2. THE CONTRACTOR WILL BE REQUIRED TO PLACE 2-#6 BARS "Y" IN THE TOP OF ALL ENDWALL FOR PIPE CULVERTS 42" AND COVER WITH A MINIMUM 3" COVER AND A LENGTH OF 6" LESS THAN ENDWALL.
3. FORMS ARE TO BE USED FOR THE CONSTRUCTION OF THE BOTTOM SLAB.
4. WALL THICKNESS (T) SHOWN IS NOT TO BE INTERPRETED TO MEAN THE THICKNESS ACCEPTABLE, BUT IS USED ONLY IN COMPUTING ENDWALL QUANTITIES.
5. IF CONTRACTOR ELECTS TO USED CONSTRUCTION JOINT AT BOTTOM OF PIPE, BAR "X" (DOWELS) SHALL BE PLACED IN THE BASE AS SHOWN ON PLANS. SPACING OF BARS TO BE APPROXIMATELY 12" CENTERS UNLESS ENGINEER DIRECTS OTHERWISE.
6. IF CONTRACTOR ELECTS TO USED CONSTRUCTION JOINT AT BOTTOM OF PIPE, AND POURS BASE SEPARATELY, THE TOP OF BASE SHALL BE LEFT ROUGH.
7. ALL CONCRETE TO BE 3600 P.S.I COMPRESSIVE STRENGTH.

APPROVED DATE \_\_\_\_\_

REVISIONS	NO.	DATE	DESCRIPTION
			

**CONCRETE WINGWALL  
WITH SPLASH PAD**

*(2 of 2)*

FILE: I:\Maps-Details\Detail Manual\Details	
DRAWN BY: JAM	DATE: 08-07-01
CHECKED BY: JNL	SCALE: N.T.S.
PREPARED BY:	
ENGINEERING DEPARTMENT	DETAIL
04.03.07	