



ELEVATION VIEW

NOTE:

VERTICAL STEEL

#10 BARS. 4'-4" LONG, 8 REQUIRED

HORIZONTAL STEEL

#10 BARS 9'-4" LONG, 8 REQUIRED

#10 BARS 3'-1 1/2" LONG, 8 REQUIRED

DIAGONAL STEEL

#10 BARS 4'-0" LONG, 4 REQUIRED

#	REVISED	DATE: 7/1/04
		SCALE: NONE
		DRAWN BY: DSW
		CHECKED BY: DSW
		APPROVED BY: DSW

STANDARD DETAIL  
BLOCKING FOR WATER MAINS  
16" - 30" DETAIL

WATER RESOURCES DEPARTMENT  
CITY OF MONROE, NC  
FILE NO. 10.13.00 DIV. NO. 10