




STREET




TOP VIEW



SIDE VIEW

LOT



STREET

SEE STANDARD SPECIFICATIONS AND DETAILS MANUAL FOR LOCAL RESIDENTIAL STREET DETAIL WITH CORRESPONDING RW FOR WATER METER AND SEWER LATERAL LOCATIONS FROM BACK OF CURB.

NOTES:

1. FOUR (4) 3' STEEL "T" FENCE POSTS SHALL BE INSTALLED AROUND THE WATER METER BOX 1' 2" BELOW GRADE, WITH 24" ABOVE GRADE.
2. ORGANGE CONSTRUCTION FENCING SHALL BE USED TO WRAP AROUND THE FOUR (4) STEEL "T" FENCE POSTS.
3. THE DEVELOPER'S SURVEYOR SHALL IDENTIFY AND STAKE THE CENTER LINE OF EACH LOT.
4. ALL WATER METER BOXES AND SANITARY SEWER LATERALS SHALL BE INSTALLED IN THE RIGHT-OF-WAY, CENTER OF THE LOT, WITH NO MORE THAN 2' OF SEPARATION BETWEEN THE WATER METER BOX AND SANITARY SEWER LATERAL, UNLESS PERMITTED BY THE WATER RESOURCES DEPARTMENT OR ITS REPRESENTATIVE.
5. SHALL NOT BE APPLICABLE TO LOTS ON CUL-DE-SACS.

#	REVISED	DATE:	3/15/08
1	4/11/2008	SCALE:	NONE
2	10/29/2015	DRAWN BY:	DSW
3	1/26/2017	CHECKED BY:	RKS
		APPROVED BY:	RKS

STANDARD DETAIL

3/4" AND 1" METER PROTECTION
DETAIL

WATER RESOURCES DEPARTMENT
CITY OF MONROE, NC

FILE NO. 10.08.01 DIV. NO. 10