



NOTE:

1. HYDRANTS TO BE SET AT EDGE OF R/W AT PROPERTY LINES.
2. BURY LINE TO BE SET AT EXISTING OR FINAL GRADE LEVEL; EXTENSIONS MAY BE NECESSARY.
3. HYDRANTS SHALL BE PAINTED YELLOW.
4. CHAINS TO BE REMOVED FROM CAPS.
5. MIN DISTANCE BETWEEN HYDRATE AND GATE VALVE SHALL BE 2'-6".

#	REVISED	DATE: 7/1/04	STANDARD DETAIL  FIRE HYDRANT INSTALLATION DETAIL	WATER RESOURCES DEPARTMENT CITY OF MONROE, NC	
1	11/1/2013	SCALE: NONE		FILE NO. 10.07.00	DIV. NO. 10
2	11/3/2015	DRAWN BY: DSW			
3	1/26/2017	CHECKED BY: RKS			
		APPROVED BY: RKS			