



NOTES:

1. VALVE BOXES SHALL BE SCREW TYPE. VALVE BOXES LOCATED IN LAWN AREA SHALL BE INSTALLED WITH CONCRETE DOUGHNUT PADS.
2. #12 GAUGE STRANDED COPPER WIRE SHALL BE BROUGHT THROUGH VALVE BOX AND HOOKED TO BOLTS ON VALVE.
3. VALVE SHALL BE CENTERED IN BOX AND LEVELED PLUMB BEFORE BACKFILL.
4. VALVE SHALL NOT SUPPORT VALVE BOX.
5. VALVE BOXES SHALL BE NO HIGHER THAN 1/4" IN ROADWAY AND NO MORE THAN 1" IN RIGHT OF WAYS.

#	REVISED	DATE:	7/1/04	STANDARD DETAIL	WATER RESOURCES DEPARTMENT
1	11/1/2013	SCALE:	NONE		CITY OF MONROE, NC
2	11/1/2015	DRAWN BY:	DSW	GATE VALVE SETTING DETAIL	FILE NO. 10.05.00
3	1/26/2017	CHECKED BY:	RKS		DIV. NO. 10
		APPROVED BY:	RKS		